

WATEROUS COMPANY

SAINT PAUL

February 2, 1948

MINNESOTA

CENTRIFUGAL PUMP CERTIFICATION SHEET

PUMP SOLD TO Minnesota Fire Equipment Co.

FOR INSTALLATION ON 1947 Ford

FOR USE AT Destination Unknown

- - - -

This is to certify that a sufficient test has been made on Pump No. 7246 of Model CA-3-500 having a diameter of 8" inches and a gear ratio, engine to pump, of 1 to 1.64, to guarantee that the following results will be obtained with a lift of approximately ten feet at an elevation not exceeding 2000 feet above sea level.

<u>DISCHARGE</u> <u>G.P.M.</u>	<u>PRESSURE AT</u> <u>DISCHARGE</u>	<u>ENGINE</u> <u>R.P.M.</u>	<u>ENGINE H.P.</u> <u>REQUIRED</u>
Capacity	120 pounds	2225	57
One-half capacity	200 pounds	2090	51
One-third capacity	250 pounds	2200	45

WATEROUS COMPANY

By George A. Rathburn
~~CHIEF~~ ENGINEER

GAR:AK